
Corby Borough Council
Environmental Services
Working towards a Cleaner Environment

ENVIRONMENTAL PERMIT

Environmental Permitting Regulations 2010
(as amended)

Installation address

Tesco Stores Ltd.
Oakley Road
Corby
Northamptonshire
NN18 9AL

Tesco Stores Ltd. is hereby permitted by Corby Borough Council to carry on an 'unloading of petrol into storage and motor vehicle refuelling at a service station' process as prescribed in the Environmental Permitting Regulations 2010 (as amended), Schedule 1, section 1.2, Part B as described below and within the installation boundary as marked red on the attached plan reference P49/Plan and in accordance with the conditions detailed in this Permit.

Signed  Date 1/10/2015

Authorised Officer of the Council

Contact Details: Corby Borough Council, Environmental Services,
Deene House, New Post Office Square, Corby,
Northants, NN17 1GD

Tel: 01536 464075 Fax: 01536 464644

4. The petrol vapour capture efficiency of the Stage II petrol vapour recovery system shall be equal to or greater than 85% but less than 115% as certified by the manufacturer in accordance with relevant European technical standards or type approval procedures.
5. Where the recovered petrol vapour is transferred to a storage tank, the vapour/petrol ratio shall be equal to or greater than 0.95 but less than or equal to 1.05.
6. Where an automatic monitoring system has been installed, the petrol vapour capture efficiency shall be tested and the results recorded at least once every three years by checking that the vapour/petrol ratio under simulated petrol flow conditions, or by any other appropriate methodology.

Any such automatic monitoring system shall automatically detect faults in the proper functioning of the Stage II petrol vapour recovery system and in the automatic monitoring system itself, indicate faults to the operator and automatically stop the flow of petrol from any faulty dispenser if the fault is not rectified within seven days.
7. Where automatic monitoring systems have not been installed the in-service petrol vapour capture efficiency of the Stage II petrol vapour recovery systems shall be tested and the results recorded at least once a year by checking that the vapour/petrol ratio under simulated petrol flow conditions, or by any other appropriate methodology.
9. A sign, sticker or other notification shall be displayed on, or in the vicinity of, the petrol dispenser, informing consumers that a Stage II petrol vapour recovery system is in use.


Incident Reporting

10. In the event of any incident at the site which could have an impact beyond the site boundary, the operator shall notify the Regulator at Corby Borough Council by telephone without delay on 01536 464075

Management

11. A copy of this permit shall be kept at the permitted installation. All staff that should be aware of its content shall be told where it is kept.
12. All relevant staff shall receive the necessary training and instruction to enable them to comply with the conditions of this permit.
13. The operator shall notify the Council of any changes to the persons nominated in the application as the primary point of contact, and deputy.
14. Maintenance and testing of vapour recovery systems shall be recorded.

Site Location Map



Site Plan

